



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/ör  veya/ör T S E

BELGE NUMARASI 009366-TSE-02/02

REFERENCE NUMBER OF LICENCE

BELGENİN İLK VERİLİŞ TARİHİ 04.01.2011

DATE OF FIRST ISSUE OF LICENCE

BELGENİN SON GEÇERLİLİK TARİHİ 06.09.2026

LICENCE VALID UNTIL

BELGE SAHİBİ KURULUŞUN ADI TEMPA PANO SANAYİ VETİCARET A.Ş.

NAME OF THE LICENCE HOLDER

BELGE SAHİBİ KURULUŞUN ADRESİ OKMEYDANI PERPA TİCARET MERKEZ NO:292 /K-5 BEYOĞLU
ADRESS OF THE LICENCE HOLDER İSTANBUL/TÜRKİYE

ÜRETİM YERİ ADI TEMPA PANO SANAYİ VE TİCARET A.Ş.

NAME OF THE MANUFACTURING PLACE

ÜRETİM YERİ ADRESİ MAKİNE VE İMALAT SANAYİCİLERİ ORGANİZE SANAYİ BÖLGESİ 2.
ADRESS OF THE MANUFACTURING PLACE CADDE NO:1 DEMİRCİLER KÖYÜ DİLOVASI KOCAELİ / TÜRKİYE

İPTAL EDİLEN BELGE NUMARASI (Varsa) 009366-TSE-02/01

INDICATION OF SUPERSEDED LICENCE (if any)

TESCİLLİ TİCARİ MARKASI TEMPA PANO

REGISTERED TRADE MARK

İLGİLİ TÜRK STANDARDI TS EN 62208 / 16.04.2014

RELATED TURKISH STANDARD

BELGE KAPSAMI

SCOPE OF LICENCE

EMPTY ENCLOSURES

- AS/BS SERIES, STEEL / FLOOR STANDING TYPE / INDOOR-OUTDOOR / IP55 / IK 10

Dimensions: WIDTH/HEIGHT/DEPTH from 600mm/600mm/400mm (included) upto 1200mm/2000mm/800mm (included)

-BK/KB SERIES, STEEL / WALL MOUNTED TYPE / INDOOR-OUTDOOR / IP65-IP66 / IK 10

Dimensions: WIDTH/HEIGHT/DEPTH from 150mm/150mm/120mm (included) upto 600mm/400mm/120mm (included)

-ETS/EKO SERIES, STEEL / WALL MOUNTED TYPE / INDOOR-OUTDOOR / IP65-IP66 / IK 10

Dimensions: WIDTH/HEIGHT/DEPTH from 200mm/300mm/150mm (included) upto 1000mm/1200mm/300mm (included)

- MS SERIES, STEEL / FLOOR STANDING TYPE / OUTDOOR / IP65 / IK 10

Dimensions: WIDTH/HEIGHT/DEPTH from 600mm/600mm/400mm (included) upto 1200mm/2000mm/600mm (included)

Note: This document does not replace TS EN 61439-2, which is the standard of Electrical Equipment assembled Low Voltage Switchgear and Control Unit.



e-imzalı/e-signed

05.05.2026

On Behalf Of The Head Of Certification Center
YUNUS MERCAN

DEPUTY MANAGER of İSTANBUL CERTIFICATION

*This certificate also shows that the production place of the certified product meets the requirements of Institute.

*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

*TSE * Address: Çayırova Tren İstasyonu Yanı ÇAYIROVA/GEBZE * Telephone: 2627231273* Fax: 2627231606

*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail bmb@tse.org.tr , web : www.tse.org.tr



Please check the accuracy and validity of the certificate from <https://evrakkontrol.tse.org.tr/BelgeDogrulama.aspx?p=ltchfprh>

1 / 1