



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx SIR 15.0057U issue No.:0 Certificate history:

Status: Current

Date of Issue: 2015-12-01 Page 1 of 3

Applicant: **Tempa Pano**
Makine İhtisas Organize Sanayi Bölgesi
2.Cad.,No:1 Demirciler Köyü
Dilovası KOCAELİ 41455
Turkey

Electrical Apparatus: **TEX & TES***** Range of Enclosures**
Optional accessory:

Type of Protection: **Increased Safety and Dust Protection by Enclosure**

Marking: Ex eb IIC Gb
Ex tb IIIC Db

Approved for issue on behalf of the IECEx Certification Body: C Ellaby

Position: Deputy Certification Manager

Signature:
(for printed version)

Date:


2015-12-01

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

SIRA Certification Service
CSA Group
Unit 6, Hawarden Industrial Park
Hawarden
Deeside
CH5 3US
United Kingdom

sira
CERTIFICATION





IECEx Certificate of Conformity

Certificate No.: IECEx SIR 15.0057U

Date of Issue: 2015-12-01

Issue No.: 0

Page 2 of 3

Manufacturer: **Tempa Pano**
Makine İhtisas Organize Sanayi Bölgesi
2.Cad.,No:1 Demirciler Köyü
Dilovası KOCAELİ 41455
Turkey

Additional Manufacturing location
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition: 6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-31 : 2013 Edition: 2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
IEC 60079-7 : 2015 Edition: 5.0	Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:
[GB/SIR/ExTR15.0308/00](#)

Quality Assessment Report:

[GB/SIR/QAR15.0005/00](#)



IECEx Certificate of Conformity

Certificate No.: IECEx SIR 15.0057U

Date of Issue: 2015-12-01

Issue No.: 0

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The TES***** range of enclosure boxes are manufactured in mild or stainless steel and comprise of an enclosure with a separate lipped lid. The lid has a closed cell, flat EPDM gasket seal that presses on to a lipped edge on the base of the enclosure, with access points for fixing lugs to secure the enclosure to the mounting surface.
The TEX***** range of enclosure boxes are manufactured in mild or stainless steel and comprise of an enclosure with a hinged lid. The lid has a closed cell poured polyurethane gasket seal that presses on to a raised edge on the base of the enclosure to aid sealing. Four fixing lugs are provided to secure the enclosure to the mounting surface. For range of Enclosure sizes, see Certificate Annexe.

Schedule of limitations

The user/installer shall comply with the following:

1. The enclosure gasket is suitable for a service temperature range of -40°C to +100°C.

Conditions of manufacture

The Manufacturer shall comply with the following:

1. The enclosures may also be manufactured to sizes not specified in the documentation provided that any given dimension is not larger than the respective dimension of the largest enclosure or smaller than the respective dimension of the smallest enclosure.

CONDITIONS OF CERTIFICATION: NO

Annexe to: IECEx SIR 15.0057U Issue 0
Applicant: Tempa Pano
Apparatus: TEX & TES***** Range of Enclosures



Enclosure sizes

Type	Width (mm)	Height (mm)	Depth (mm)
TES121208	120	120	80
TES151509	150	150	90
TES191910	190	190	100
TEX152213	150	220	130
TEX262616	260	260	160
TEX262620	260	260	200
TEX303016	300	300	160
TEX303020	300	300	200
TEX263816	260	380	160
TEX263820	260	380	200
TEX384516	380	450	160
TEX384520	380	450	200
TEX484816	480	480	160
TEX484820	480	480	200
TEX355016	350	500	160
TEX355020	350	500	200
TEX456216	450	620	160
TEX456220	450	620	200
TEX745520	740	550	200
TEX507620	500	760	200
TEX648620	640	860	200
TEX619120	610	910	200
TEX749820	740	980	200

Sira Certification Service

Unit 6, Hawarden Industrial Park,
Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670 900
Fax: +44 (0) 1244 539 301
Email: ukinfo@csagroup.org
Web: www.csagroupuk.org