



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/or  veya/or **T S E**

BELGE NUMARASI 009366-TSE-01/02
REFERENCE NUMBER OF LICENCE

BELGENİN İLK VERİLİŞ TARİHİ 05.02.2015
DATE OF FIRST ISSUE OF LICENCE

BELGENİN SON GEÇERLİLİK TARİHİ 31.12.2026
LICENCE VALID UNTIL

BELGE SAHİBİ KURULUŞUN ADI TEMPA PANO SANAYİ VETİCARET A.Ş.
NAME OF THE LICENCE HOLDER

BELGE SAHİBİ KURULUŞUN ADRESİ OKMEYDANI PERPA TİCARET MERKEZ NO:292 /K-5 BEYOĞLU
ADDRESS OF THE LICENCE HOLDER İSTANBUL/TÜRKİYE

ÜRETİM YERİ ADI TEMPA PANO SANAYİ VE TİCARET A.Ş.
NAME OF THE MANUFACTURING PLACE

ÜRETİM YERİ ADRESİ MAKİNE VE İMALAT SANAYİCİLERİ ORGANİZE SANAYİ BÖLGESİ 2.
ADDRESS OF THE MANUFACTURING PLACE CADDE NO:1 DEMİRCİLER KÖYÜ DİLOVASI KOCAELİ / TÜRKİYE

İPTAL EDİLEN BELGE NUMARASI (Varsa) 009366-TSE-01/01
INDICATION OF SUPERSEDED LICENCE (if any)

TESCİLLİ TİCARİ MARKASI TEMPA PANO
REGISTERED TRADE MARK

İLGİLİ TÜRK STANDARDI TS EN IEC 61439-2 / 30.09.2021 -- TS EN IEC 61439-1 / 30.09.2021
RELATED TURKISH STANDARD

BELGE KAPSAMI
SCOPE OF LICENCE

Low voltage switchgear and control assemblies
Type/Model : LVP5000
Type according to area of use : Low-voltage power distribution switchgear
Type according to the design : Multi-cabined - Welded and bolted
Type according to the plant conditions : Indoor plant / stationary switchgear
Nominal Voltage (Ue): 400V AC 3Phase + N +PE
Main Circuit Impulse Withstand Voltage (Uimp) : 8 kV
Isolation Voltage (Ui): 690V
Nominal Current and Diversity Factor (Ina) : 5000A /1
Nominal current of each circuit of diversity factor (Inc) :
IP 44 Protection Class :
Incoming : 5000A (1.0 X 5000A)
Outgoing1 : 2250A (0,9 X 2500A)

e-imzalı/e-signed

12.01.2026

On Behalf Of The Head Of Certification Center
YUNUS MERCAN

DEPUTY MANAGER of İSTANBUL CERTIFICATION

*This certificate also shows that the production place of the certified product meets the requirements of Institute.

*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

*TSE * Address: Çayirova Tren İstasyonu Yanı ÇAYIROVA/GEBZE * Telephone: 2627231273* Fax: 2627231606

*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail :bmb@tse.org.tr , web : www.tse.org.tr





TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/or  veya/or **T S E**

(009366-TSE-01/02nolu belge devamı) : **TEMPA PANO SANAYİ VETİCARET A.Ş.**

İLGİLİ TÜRK STANDARDI(RELATED TURKISH STANDARD) TS EN IEC 61439-2 / 30.09.2021 -- TS EN IEC 61439-1 / 30.09.2021

Outgoing2 : 1008A (0,63 X 1600A)
Outgoing3 : 397A (0,63 X 630A)
Outgoing4 : 252A (0,63 X 400A)
Outgoing5 : 252A (0,63 X 400A)
Outgoing6 : 158A (0,63 X 250A)
Outgoing7 : 101A (0,63 X 160A)
Outgoing8 : 63A (0,63 X 100A)
Outgoing9 : 40A (0,63 X 100A)

IP 32 Protection Class :

Incoming : 5000A (1.0 X 5000A)
Outgoing1 : 2352A (0,93 X 2500A)
Outgoing2 : 1152A (0,72 X 1600A)
Outgoing3 : 454A (0,72 X 630A)
Outgoing4 : 288A (0,72 X 400A)
Outgoing5 : 288A (0,72 X 400A)
Outgoing6 : 180A (0,72 X 250A)
Outgoing7 : 115A (0,72 X 160A)
Outgoing8 : 72A (0,72 X 100A)
Outgoing9 : 45A (0,72 X 63A)

Frequency (Fn) :50 Hz

Command , Control and Qualification of protection device (Brand and model):

SCHNEIDER, NW50H1 3P ML2EW 100kA (5000A)

SCHNEIDER, NW25H2 3P ML2EW 85kA (2500A)

SCHNEIDER, NS1600N 50kA (1600A)

SCHNEIDER, NSX630H 70kA (630A)

SCHNEIDER, NSX400H 70kA (400A).....2 pieces

SCHNEIDER, NSX250H 70kA (250A)

SCHNEIDER, NSX160H 70kA (160A)

SCHNEIDER, NSX100H 70kA (100A)

SCHNEIDER, NSX100H 70kA (63A)

Equipment Dimensions (mm) : H2250mm x D1000mm x W(600 + 1000 + 400 + 600 + 400)mm

Weight of the most bigger equipment (kg) : 2409

External protection class (IP) :32/44

Mechanical impact protection class : IK 10

Equipment internal separation format : Form4b Type 7

Grounding system type of the designed panel : TN-S

Pollution degree : 3-(Material group IIIa)

Cooling type of the panel (Natural / forced) : Natural

Transport type of the panel (Top / Bottom) : Top / Bottom

Locking system (Brand / model) : MESAN

Hinge Model : ATOS

e-imzalı/e-signed

12.01.2026

On Behalf Of The Head Of Certification Center
YUNUS MERCAN

DEPUTY MANAGER of İSTANBUL CERTIFICATION

*This certificate also shows that the production place of the certified product meets the requirements of Institute.

*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

*TSE * Address: Çayirova Tren İstasyonu Yanı ÇAYIROVA/GEBZE * Telephone: 2627231273* Fax: 2627231606

*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail :bmb@tse.org.tr , web : www.tse.org.tr





TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS



(009366-TSE-01/02nolu belge devamı) : **TEMPA PANO SANAYİ VE TİCARET A.Ş.**

İLGİLİ TÜRK STANDARDI (RELATED TURKISH STANDARD) TS EN IEC 61439-2 / 30.09.2021 -- TS EN IEC 61439-1 / 30.09.2021

Filter Brand , model , quantity , dimensions : PFANNENBERG PFA1000-8 pcs. / PFA3000-13 pcs.

Support Brand / Model : TEMPA support

EMC CLASS : ENVIROMENT A

Rated shorth-time withstand current and peak withstand current : (Icw,Ipk)

* Secondary circuit shorth-time withstand current (Icw) and duration (sec) of the switchgear (SCHNEIDER, NW25H2 3P ML2EW) Effective: 85kA/1 sec Peak: 187 kA

* Main circuit shorth-time withstand current (Icw) and duration (sec) of the switchgear (SCHNEIDER, NW50H1 3P ML2EW) Effective: 100kA/1 sec Peak: 220 kA

* Secondary circuit shorth-time withstand current (Icw) and duration (sec) of the switchgear (Secondary busbar) Effective: 70kA/1 sec Peak: 154 kA

* Ground circuit shorth-time withstand current (Icw) and duration (sec) of the switchgear (Ground busbar) Effective: 60kA/1 sec Peak: 132 kA

* Rated conditional short circuit current (Icc)

Conditional shorth circuit current of the shorth circuit protective device (Icc)
70kA/154kA , SCHNEIDER , NSX100H 70 kA (63A)

Conditional shorth circuit current of the shorth circuit protective device (Icc)
70kA/154kA , SCHNEIDER , NSX100H 70 kA (100A)

Conditional shorth circuit current of the shorth circuit protective device (Icc)
70kA/154kA , SCHNEIDER , NSX160H 70 kA (160A)

Conditional shorth circuit current of the shorth circuit protective device (Icc)
70kA/154kA , SCHNEIDER , NSX250H 70 kA (250A)

Conditional shorth circuit current of the shorth circuit protective device (Icc)
70kA/154kA , SCHNEIDER , NSX400H 70 kA (400A).....2 pcs

Conditional shorth circuit current of the shorth circuit protective device (Icc)
70kA/154kA , SCHNEIDER , NSX630H 70 kA (630A)

Conditional shorth circuit current of the shorth circuit protective device (Icc)
50kA/110kA , SCHNEIDER , NS1600N 50 kA (1600A)

Conditional shorth circuit current of the shorth circuit protective device (Icc)
85kA/187kA , SCHNEIDER , NW25H2 3P ML2EW 85kA (2500A)

Conditional shorth circuit current of the shorth circuit protective device (Icc)
100kA/220kA , SCHNEIDER , NW50H1 3P ML2EW 100kA (5000A)

e-imzalı/e-signed

12.01.2026

On Behalf Of The Head Of Certification Center
YUNUS MERCAN

DEPUTY MANAGER of İSTANBUL CERTIFICATION

*This certificate also shows that the production place of the certified product meets the requirements of Institute.

*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

*TSE * Address: Çayırova Tren İstasyonu Yanı ÇAYIROVA/GEBZE * Telephone: 2627231273* Fax: 2627231606

*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail :bmb@tse.org.tr , web : www.tse.org.tr

