



**TSE QUALITY CAMPUS REGIONAL DIRECTORATE
ELECTRICAL LABORATORY**

Çayırova 41410 GEBZE/KOCAELI TURKEY Phone: +902626530751(30lines) Fax:+902626530838
e-mail: elektriklab@kampus.tse.org.tr URL: www.kampus.tse.org.tr

41.16.01

500582

04 - 05

TESTING REPORT

Customer (Name, Adress City etc.) : Tempa Pano San. Ve Tic. Ltd. Şti.
Order Date/No. : 27.04.2005/500592
Sample Description(Type, Mark, Model etc.) : Panel, BS-060640, 1 piece
Sample Receipt Date : 27.04.2005
Date of Test : 27.04.2005 – 28.04.2005
Applied Standard/ Method : TS 3033 EN 60529/1997-03 “Protection degrees providing with casing (IP code) (in electrical equipments)”
Number of pages of the report : 2
Remarks : Nr. Origin : Tempa Pano San. Ve Tic. Ltd. Şti.

The testing and / or measurement results are given on the following pages which are part of this report.

Seal	Date	Person in charge of test	Division Responsible	Head Of Laboratory
Seal	28.04.2005	- Signature- H.Hüseyin AYABAKAN Electrician	- Signature - Cem KAZEL Professional Electrical Engineer	-Signature - Ahmet Nursi KARTALY


This report shall not be reproduced other than in full except with the permission of the laboratory. Test reports without signature and seal nor valid.

This is to certify that the above translation from Turkish into ..English..... is correct and authentic with the original Translator, officially sworn by Notary Public


İş bu belge Türkçe aslından İngilizceye tarafımdan tercüme edilmiştir. Yeminli Tercüman Uğur ZUBOĞLU


41.02.00.R. 001/13.08.2004-2



	TSE QUALITY CAMPUS REGIONAL DIRECTORATE	Regional Code: 41.16.01.06
	ELECTRICITY LABORATORY	Report No. 500582
	EXAMINATION AND TEST REPORT	Date: 28.04.2005

**ENCLOSURE PICTURES ON
ORIGINAL DOCUMENT**



	TSE QUALITY CAMPUS REGIONAL DIRECTORATE	Regional Code: 41.16.01.06
	ELECTRICITY LABORATORY	Report No. 500582
	EXAMINATION AND TEST REPORT	Date: 28.04.2005

Type of Examination: Ö.D.

Date and Number of The Document: 27.04.2005 / 1164

Test results which were performed on the panel sample delivered by the company “**TEMPA PANO SAN. VE TİC. LTD. ŞTİ.**” with the petition dated 27.04.2005 in accordance with the TS 3033 EN 60529 IP 55 Protection Class, have been listed below.

TESTS:

1. THE TEST RELATING TO PREVENTION OF REACHING TO THE DANGEROUS SECTIONS AND PROTECTION AGAINST THE UNKNOWN SOLID MATERIALS (IP5X):

2. At the end of the test which was performed by the test method and Test Contrivance Against The Unknown Solid Materials (Dust) as specified in the standard, it was observed that the dust didn't diffuse into the sample. The protection was detected satisfactory.

2. TEST RELATING TO PROTECTION AGAINST WATER (IP X5):

At the end of the test which was performed by the test method and test contrivance as specified in the standard, it was observed that the water didn't diffuse into the sample. The protection was detected satisfactory.

It is to certify that this report was prepared as 3 pages and 2 copies on the date 28.04.2005.

(Seal and Signature)

